

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	Circuit-breakers (MCCB)
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R. China 325603
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	See page 2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	NB1-63H
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	210401212SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden



Signature:



Henrik wikström

Date: 15 June, 2021

Ratings and principal characteristics

Ue= 220/230/240V for 1P, 400/415V for 2P, 3P, 4P
In= 1, 2, 3, 4, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63A;
Icu= 10kA, Ics= 7,5kA
Cat. A, Uimp=6kV, Ui=500V, 50/60Hz
ref. temperature +30°C, +40°C and +50°C
Ii= 4In, 8,5In, 10In, 12In

Date: 15 June, 2021

Signature:

