

  
Intertek **CERTIFICATE**  
**FOR EUROPEAN PRODUCT SAFETY**

Reference No. SE-S-2200720R3

**Circuit-breakers for overcurrent protection  
for household and similar installations  
(CBOs)**

**Type designation:** NB1-63, NB1-63H

**Certificate holder:** Zhejiang Chint Electrics Co., Ltd.  
No.1, Chint Road, Chint Industrial Zone, North Baixiang,  
Yueqing, Zhejiang Province, P.R.China

**The product complies with  
the standard(s):** EN 60898-1:2019

**Date of expiry:** 13 June, 2027

**EU Directive information:** According to the principle of presumption of conformity, this certificate  
constitutes support for an EU Declaration of Conformity to the Low  
Voltage Directive 2014/35/EU.

Additional information in Appendix

**Certification Body:** Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

**Signed:**  **Date:** 16 November, 2023

Fredrik Wennersten

## APPENDIX:

Reference No. SE-S-2200720R3

### Technical Data:

Type designation	NB1-63, NB1-63H
Rated voltage (V)	110 or 230/400 or 240/415V~(1P), 230 or 240V~(1P+N), 110 or 400 or 415V~(2P), 400 or 415V~ (3P, 3P+N, 4P)
Rated current (A)	1, 1,6, 2, 3, 4, 5, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63A (30°C) 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A (55°C)
Frequency (Hz)	50/60Hz
IP-Class	IP20
Poles No.	1P, 1P+N, 2P, 3P, 3P+N, 4P

### Trademark



### Test Report

230100201SHA-001,  
230100201SHA-001 M1

### Product information

Ics= 7500A, Icn=10000A (for NB1-63H)  
Ics= Icn= 6000A (for NB1-63)  
B-, C- & D- type, Energy limiting class 3.

### Manufacturing Sites:

Zhejiang Chint Electrics Co., Ltd.  
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,  
Zhejiang Province, P.R.China

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU. This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.


This certificate replaces previously issued certificate ref. No. SE-S-2200720R2 dated 13 January 2023 for the same model. A new certificate has been issued on account of adding "110V~" to 1P and 2P.

### Certification Body:

Intertek Semko AB, Product Certification

Place: Kista - Stockholm

### Signed:



Date: 16 November, 2023

Fredrik Wennersten