

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded Case Circuit Breaker

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town,
Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town,
Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

NOARK Electrics (Shanghai) Co., Ltd.
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NM8N-400HV, NM8N-630HV;

Additional information (if necessary may also be reported on page 2)

Original CB certificate No. is CN55015, dated 2021-10-18. The first modification is to change parameters.

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016/AMD1:2019; IEC 60947-2:2016(5th Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-099302-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE


Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: May.05,2022

Signature:



Xie ZhaoXu



NM8N-400HV, NM8N-630HV

Uimp: 12kV;

Ui: 1250V;

Ue: AC690V, AC800V, AC1000V, AC1150V;

In: 250A, 315A, 350A, 400A, 500A, 630A;

Over-current release type: Thermal-magnetic, Electromagnetic;

Ics: See table below;

Icu: See table below;

Selectivity category: A;

Rated frequency: 50/60Hz;

Suitable for isolation;

3P;

Auxiliary contact: AX21-M8, AL21-M8;

1NO1NC;

Ith: 5A;

AC-15: Ue/Ie: AC110V/5A, AC240V/4A, AC415V/2A;

DC-13: Ue/Ie: DC110V/0.25A, DC220V/0.25A;

Electronic accessories complied with Annex N:

Undervoltage release(Model type: UVT22-M8): AC48V, AC110V, AC220~240V, AC380~415V, DC24V,DC48V, DC110~120V, DC220V

In	Ue	Icu(kA)		Ics(kA)	
		C	S	C	S
250A, 315A, 350A, 400A, 500A, 630A	AC690V	50	80	50	80
	AC800V	36	50	36	50
	AC1000V	25	35	15	20
	AC1150V	10	10	10	10


Page 1 of 1

Additional information (if necessary)

Date:

May.05,2022

Signature:



Xie ZhaoXu