

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
R 50401999

Blatt *Sheet*  
0001

Ihr Zeichen *Client Reference*  
B.W.

Unser Zeichen *Our Reference*  
01-DY-15044624 003

Ausstellungsdatum *Date of Issue*  
22.03.2018  
(day/mo/yr)

## Genehmigungsinhaber *License Holder*

Zhejiang Chint Electric Co., Ltd.  
No.1,  
Chint Road, Chint Industrial Zone,  
North Baixiang  
Yueqing, Zhejiang Province 325603  
P. R. China

## Fertigungsstätte *Manufacturing Plant*

Zhejiang Chint Electric Co., Ltd.  
No.1,  
Chint Road, Chint Industrial Zone,  
North Baixiang  
Yueqing, Zhejiang Province 325603  
P. R. China

## Prüfzeichen *Test Mark*

Geprüft nach *Tested acc. to*  
EN 60947-5-1:2017



Zertifiziertes Produkt (Geräteidentifikation)  
*Certified Product (Product Identification)*

Lizenzentgelte - Einheit  
*License Fee - Unit*

## Auxiliary Contacts (Auxiliary Contact)

Type Designation : XF9 ; XF9J

6

Utilization Category: Rated Operational Voltage/Current  
AC-12: AC415V/3A; AC240V/6A  
DC-12: DC130V/1A; 48V/2A; 24V/6A

Conventional Free Air

Thermal Current : 6A

rated insulation voltage : 500V

rated conditional

short-circuit current : 1kA

IP code : IP20

6

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.  
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel: +49 221 806-1371 e-mail: cert-validity@de.tuv.com

Fax: +49 221 806-3935 http://www.tuv.com/safety



Lecham Zhuang