



ATTESTATION of conformity with European Directives

Product: Residual current protection circuit-breaker
Reference NBTL-2P
Issued to Zhejiang Chint Electric Co., Ltd.
Address No.1 CHINT Road, CHINT Industrial Zone, North Baixiang, Yueqing
Manufacturer Zhejiang Chint Electric Co., Ltd.

Technical characteristics Ue: 240V~(1P+N), 50/60Hz
Selectivity category: A
Ie: 15A;30A;45A;60A
Icu=Ics=6kA
Ui=415V
Uimp=6kV
IP50
Pollution degree: 3
Reference temperature: 40°C
Distance for metal screen:
Back:0mm Front:0mm; Top:0mm Botton:0mm; Left:0mm
Right:0mm(values declared by client)

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60947-2:2017+A1:2020 EN 60947-1:2007 + A1:2011 + A2:2014	CNT-ESH-P22100887	05/12/2022

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), December 12nd, 2022.

Charlie CHEN
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有
限公司

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com