IEC IECEE CB SCHEME

Ref. Certif. No.

HU-002473

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

| | |
|---|---|
| Product | Circuit breaker for overcurrent protection |
| Name and address of the applicant | Zhejiang Chint Electrics Co., Ltd.<br>No.1, Chint Road, Chint Industrial Zone,<br>North Baixiang, Yueqing, Zhejiang Province, P.R. China |
| Name and address of the manufacturer | Zhejiang Chint Electrics Co., Ltd.<br>No.1, Chint Road, Chint Industrial Zone,<br>North Baixiang, Yueqing, Zhejiang Province, P.R. China |
| Name and address of the factory<br>Note: *When more than one factory, please report on page 2* | Zhejiang Chint Electrics Co., Ltd.<br>No.1, Chint Road, Chint Industrial Zone,<br>North Baixiang, Yueqing, Zhejiang Province, P.R. China |
| Ratings and principal characteristics | AC Ratings:<br>Ue = 220/380V, 230/400V, 240/415V~ (1P);<br>380/400/415V~ (2/3/4P); B/C/D-type; In=1A, 2A, 3A, 4A,<br>6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;<br>Icn=Ics=6kA.<br>DC Ratings:<br>Ue = 60V/110V DC (1P); 125V/220V DC (2P); B/C-type;<br>In=1A, 2A, 3A, 4A, 6A, 10A, 16A, 20A, 25A, 32A, 40A,<br>50A, 63A; Icn=10kA(60V/125V), 6kA(110V/220V);<br>Ics=7,5kA(60V/125V), 6kA(110V/220V) |
| Trademark (if any) | CHINT |
| Customer's Testing Facility (CTF) Stage used | --- |
| Model / Type Ref. | CB-60A, CB-60G |
| Additional information (if necessary may also be reported on page 2) | --- |
| A sample of the product was tested and found to be in conformity with | IEC 60898-1:2015<br>IEC 60898-2:2000 + AMD1:2003<br>EU Group Differences |
| As shown in the Test Report Ref. No. which forms part of this Certificate | 1W181054-1 (with 1W181054-2) |

This CB Test Certificate is issued by the National Certification Body

TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.com

TÜV Rheinland InterCert Kft. TÜVRheinland® 1. Product Certification

Date: 2019-01-28

Signature: Gabor Kassai