



Ref. Certif. No.  
**SE-105291M1**

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**

**CB TEST CERTIFICATE**

Product	Circuit-breakers(MCCB)
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, 325603 P.R.China
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	See page 2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	NB1-63
Additional information (if necessary may also be reported on page 2)	See Page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	210401215SHA-001, 210401215SHA-001M1

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden



Signature:

Quan Li

Date: 21 July, 2022

**Rating and principal characteristics**

Ue= 230/240V for 1P, 400/415V for 2P, 3P, 4P; 50/60Hz  
In= 1, 2, 3, 4, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63A.  
Icu= Ics= 6kA, Cat. A, Uimp=4kV, Ui=500V  
ref. temperature +30°C, +40°C and +50°C  
Ii= 4In, 8,5In, 10In, 12In, 14,5In

**Additional information**

This certificate replaces previously issued ref. No. SE-105291 dated 24 June 2021. A new certificate has been issued due to:

- Instantaneous parameter Ii=14,5In was added.

Date: 21 July, 2022

Signature: 