Ref. Certif. No.

SE-103760

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Circuit-breakers with overcurrent protection
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.China, 325603
Name and address of the manufacturer	Same as applicant
Name and address of the factory Note: *When more than one factory, please report on page 2*	Same as applicant
Ratings and principal characteristics	Un= 240/415V~ (1P), 415V~ (2P,3P, 4P) In= 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A
Trademark (if any)	CHNT
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	NB7
Additional information (if necessary may also be reported on page 2)	See page 2
A sample of the product was tested and found to be in conformity with	IEC 60898-1:2015+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	201201176SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

intertek

Signature:

Leif Mattsson

Date: 26 January, 2021

Additional information

General Product information
Ue= 240/415V~(1P), 415V~(2P, 3P, 4P)
In=1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A, B-, C- and D- type
Icn= 6000A (type B1~B40, C1~C40), 4500A (type B50~B63, C50~C63; type D1~D63)
Ics= 6000A (type B1~B40, C1~C40), 4500A (type B50~B63, C50~C63; type D1~D63)

The product has also been checked according to EN 60898-1:2019

Date: 26 January, 2021

Signature: