Ref. Certif. No.

CN52224

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Miniature Circuit-breakers
Name and address of the applicant	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the manufacturer	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the factory Note: *When more than one factory, please report on page 2*	Zhejiang CHINT Electrics Co., Ltd. No.1 CHINT Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.China
Ratings and principal characteristics	Uimp:4kV; Ui:500V; Ue: AC230V/400V(1P), AC400V(2P,3P,4P); In:1A,2A,3A,4A,6A,10A,16A,20A,25A,32A,40A; Type of instantaneous tripping current: Type B, Type C, Type D; Ics=Icn:6000A(Type B, Type C); Ics=Icn:4500A(Type D); 1P,2P,3P,4P
Trademark / Brand (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	NB8-40J
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60898-1:2002(1st Edition) + AMD 1:2002 + AMD 2:2003
As shown in the Test Report Ref. No. which forms part of this Certificate	03601-A-20CB0080-S

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn

Date: Dec.22,2020

Signature: Lu Mei

CB 0059070