



Ref. Certif. No.

SE-108758M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product: Circuit-breakers for overcurrent protection for household and similar installations (CBOs)

Name and address of the applicant: Zhejiang Chint Electrics Co., Ltd. No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.China

Name and address of the manufacturer: Same as applicant

Name and address of the factory: Same as applicant

Note: When more than one factory, please report on page 2. [ ] Additional Information on page 2

Ratings and principal characteristics: See page 2

Trademark / Brand (if any): CHINT

Customer's Testing Facility (CTF) Stage used: -

Model / Type Ref.: NXB-63H

Additional information (if necessary may also be reported on page 2): [x] Additional Information on page 2

A sample of the product was tested and found to be in conformity with: IEC 60898-1:2015+A1

As shown in the Test Report Ref. No. which forms part of this Certificate: 220500315SHA-001, 220500315SHA-001A1, 220500315SHA-001A2

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB, Torshamnsgatan 43, Box 1103, SE-164 22 Kista, Sweden, Date: 22 July, 2024

intertek logo, Signature: Håkan Eriksson



Ref. Certif. No.

**SE-108758M2**

### Ratings and principal characteristics

Un= AC220V/230V/240V (1P, 1P+N)  
Un= AC380V/400V/415V (2P, 3P, 3P+N, 4P)  
In= 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A  
Ics= 7500A, Icn= 10000A  
B-, C- & D- type, with switched neutral

### Additional information

This certificate replaces previously issued certificate ref. No. SE-108758M1 dated 29 November 2022 due to adding an alternative enclosure of grey color and updating standard from "AS/NZS 60898.1:2004 to "AS/NZS 60898.1:2024".

The requirements for EN 60898-1:2019, BS EN 60898-1:2019 and AS/NZS 60898.1:2024 have also been checked.

Date: 22 July, 2024

Signature: *Håkan Eriksson*