

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Miniature Circuit-breakers

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang CHINT Electrics Co., Ltd.
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NXB-80,NXB-80E;

Additional information (if necessary may also be
reported on page 2)The latest CB certificate No. is CN59071, dated
2023-02-17. The M1 modification is to change parameters.A sample of the product was tested and found
to be in conformity withIEC 60898-1:2015/AMD1:2019;IEC 60898-1:2015(2nd
Edition)As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2022CQC-105391-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE


Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: May.30,2023

Signature:


Xie ZhaoXu

CB 0073647

NXB-80,NXB-80E

Uimp: 4kV;

Ui: 500V;

Ue: AC220V/230V/240V(1P,1P+N,2P),AC380V/400V/415V (2P,3P,3P+N,4P);

In: 70A, 80A;

Instantaneous tripping current: B,C,D;

Icn1:6000A,10000A(Only 2P,AC220V/230V/240V);

Icn:6000A,10000A(Only 2P,AC220V/230V/240V);

Ics:6000A,7500A(Only 2P,AC220V/230V/240V);

Poles: 1P,1P+N(1 protected pole with a switched neutral pole),2P,3P,3P+N(3 protected pole with a switched neutral pole),4P;

Applicable for isolation

Page 1 of 1

Additional information (if necessary)

Date: May.30,2023

Signature:

谢肇煦
Xie ZhaoXu