



Ref. Certif. No.

HU-004581

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

DC circuit breaker

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road,Chint Industrial Zone, North Baixiang
Yueqing, 325603 Zhejiang
P.R. China

Name and address of the manufacturer

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road,Chint Industrial Zone, North Baixiang
Yueqing, 325603 Zhejiang
P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road,Chint Industrial Zone, North Baixiang
Yueqing, 325603 Zhejiang
P.R. China

Ratings and principal characteristics

Type of release: Thermo-magnetic; Selectivity Category: A;
2P appearance; Ue=80VDC; In=80/100/125A; Icu=Ics=10kA;
Uimp=4kV; Ui=500V

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

CB-125CXZ

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

CN23USFV 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2023-09-12

Signature:

Wencai Zhang

10/061SMD 2022-07 rke-fix