	Ref. Certif. No.
	HU-003021

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	DC Miniature Circuit Breaker
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province P.R. China
Name and address of the manufacturer	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province P.R. China
Name and address of the factory Note: *When more than one factory, please report on page 2*	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province P.R. China
Ratings and principal characteristics	Cat. A; Type of release: Thermo-magnetic; 1P, 2P; Ue=250V DC(1P), 500V DC(2P); In: 1/2/3/4/6/10/16/20/25/32/40/50/63A; Ui=500V; Uimp=6,0kV; Ics=Icu=6kA; Instantaneous Tripping Curve: Ii=5,5In(B type), 8,5In(C type) (see Test item particulars of Test report for further details)
Trademark / Brand (if any)	CHNT
Customer's Testing Facility (CTF) Stage used	---
Model / Type Ref.	CB-63DC
Additional information (if necessary may also be reported on page 2)	---
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016+AMD1:2019
As shown in the Test Report Ref. No. which forms part of this Certificate	1C200686

This CB Test Certificate is issued by the National Certification Body

TÜVRheinland®

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2020-10-19

Signature:

Gabor Kassai