


# Test Verification of Conformity

Verification Number: 220100117SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant  mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Zhejiang Chint Electrics Co., Ltd. No 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.China
Manufacturing site Name & Address:	Same as applicant
Product Description:	Moulded Case Circuit-breakers (MCCB)
Ratings & Principle Characteristics:	See page 2
Models/Type References:	NXB-125** (see page 3)
Brand Name(s):	
Standard(s)/Directive(s):	EN 60947-2:2017+A1:2020 Low Voltage Directive 2014/35/EU
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2021-05-27 to 2021-07-09 2021-07-22 to 2021-09-10 2022-02-21 to 2022-04-26
Test Report Number(s):	220100117SHA-001, 220100117SHA-002




Signature


**Name: Oliver Wei**  
**Position: Manager**  
**Date: 07 May 2022**

## APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 220100117SHA-V1.

### Technical Data:

Type designation	NXB-125**					
Trade mark						
Number of poles	1P			2P		
Rated operational voltage Ue (V)	60VDC	80VDC	110VDC	80VDC	125VDC	220VDC
Rated current In (A)	63, 80, 100, 125A					
Rated ultimate short-circuit breaking capacity Icu (kA)	20kA	10kA	10kA	20kA	20kA	10kA
Rated service short-circuit breaking capacity Ics (kA)	15kA	7,5kA	7,5kA	15kA	15kA	7,5kA
Test report	220100117SHA-001					
Product information	Utilization category: A, Uimp= 4kV, Ui= 500V					

Type designation	NXB-125**	
Trade mark		
Number of poles	1P	2P, 3P, 4P
Rated operational voltage Ue (V)	220/230/240 VAC	380/400/415 VAC
Rated current In (A)	63, 70, 80, 90, 100, 125A	
Rated ultimate short-circuit breaking capacity Icu (kA)	10kA	
Rated service short-circuit breaking capacity Ics (kA)	7,5kA	
Test report	220100117SHA-002	
Product information	Utilization category: A, Uimp= 4kV, Ui= 500V	

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 220100117SHA-V1.

**Explanation of type designation NXB-125\*\*:**

1st \* denotes the number of poles: 1P, 2P, 3P, 4P

2nd \* denotes the rated current In without "A": 63, 70, 80, 90, 100, 125



Signature

Name: Oliver Wei

Position: Manager

Date: 07 May 2022

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.