



Ref. Certif. No.

SE-110817

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBO's)

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, 325603 P.R.China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Same as applicant

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

Un= 230V~(1P+N, switched neutral pole), 50/60Hz
In= 1, 2, 3, 4, 6, 10, 13, 16, 20, 25A, B- & C-type
IΔn= 30mA, type-A Icn= Ics= 6000A
IΔm=500A(for IEC61009), IΔm=2000A(for F2 of EN61009)

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

NB1L

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61009-1:2010+A1+A2,
IEC 61009-2-1:1991

As shown in the Test Report Ref. No. which forms part of this Certificate

230202310SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden



Date: 18 April, 2023

Signature:

Quan Li