

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**CB TEST CERTIFICATE****Product**

Residual current operated circuit-breakers with integral overcurrent protection (RCBO)

**Name and address of the applicant**Zhejiang Chint Electrics Co., Ltd.  
No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603  
Zhejiang, China**Name and address of the manufacturer**Zhejiang Chint Electrics Co., Ltd.  
No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603  
Zhejiang, China**Name and address of the factory**Zhejiang Chint Electrics Co., Ltd.  
No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603  
Zhejiang, China*When more than one factory* [Additional information on page 2](#)**Ratings and principal characteristics****Product data**

Ratings: 1P+N

Ue: 220 / 230 / 240 Vac, 50 / 60 Hz,

In: 2, 4, 6, 10, 13, 16, 20, 25, 32, 40 A, B and C type,

I $\Delta$ n: 30, 100, 300 mA

type A and AC, without time-delay

Ics = 4,5 kA / 6 kA / 7,5 kA, Icn = 4,5 kA / 6 kA / 10 kA, I $\Delta$ m = 3 kA

The grid distance "a": 50 mm

See additional page for further ratings

**Trademark / Brand (if any)**

CHINT

**Customer's Testing Facility (CTF) Stage used****Model / Type Ref.**

NB1L

**Additional information** [Additional information on page 2](#)**A sample of the product was tested and found to be in conformity with**IEC 61009-1:2010, IEC 61009-1:2010/AMD1:2012,  
IEC 61009-1:2010/AMD2:2013 and IEC 61009-2-1:1991**National differences:**

AU

**As shown in the Test Report Ref. No. which forms part of this Certificate**3330831.50, 3318200.50, 3316675.50, 3314711.50, 3310241.50,  
3306652.50, 3302588.52, 3302588.50 and W0811042.50

This CB Test Certificate is issued by the National Certification Body



Ref. Certif. No.

NL-106848

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

[Additional information](#)

Energy limiting class 3 according to EN 61009-1:2012 + A1:2014 + A2:2014 + A11:2015 + A12:2016 + A13:2021.  
Ambient air temperature: -25 °C to 40 °C (-25 °C was tested according to EN 61009-1:2012 + A1:2014 + A2:2014 + A11:2015 + A12:2016 + A13:2021).

This certificate replaces CB NL-67415 issued on 2020-08-31.  
The tests were performed in 2009, 2011, 2014, 2016, 2018, 2019, 2020 and 2024.

[This CB Test Certificate is issued by the National Certification Body](#)

DEKRA Certification B.V.  
Meander 1051  
6825 MJ Arnhem  
Netherlands



Date: 5 May 2024

Signature: May Liu