



A P P R O V A L S ®

## Certificate of Conformity/Approval

**Certificate No.:** SAA-231868-EA

**Certificate Holder:** Zhejiang Chint Electrics Co., Ltd  
No. 1, Chint Road, Chint Industrial Zone,  
North Baixiang, Yueqing,  
Zhejiang Province, 325603  
P.R. China

**Regulatory Definition:** Residual Current Device

**Product Description:** Residual Current Operated Circuit-breakers with Integral  
Overcurrent Protection for Household and  
Similar Uses (RCBOs)

**Standard/s:** AS/NZS 61009.1:2015

**Condition/s:** Type AC RCDs are not approved under the NSW  
Recognised External Approval Scheme

**Comment/s:** Suitable for sale in New Zealand subject to compliance  
with the Electricity (Safety) Regulations

**Approval Marks:** RCM (In accordance with AS/NZS 4417 and EESS requirements)  
and  
SAA-231868-EA (In accordance with NSW legislative requirements)

**Initial Issue Date:** 11 December 2023

**Expiry Date:** 11 December 2028


For and on Behalf of  
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 11-12-23 231868  
Page 1 of 2



A P P R O V A L S ®

## Certificate of Conformity/Approval

**Model**  
NB3L-40

**Trade Name**  
CHINT

**Rating/Marking**

Un=400V/415V~ (3P+N), 50/60Hz, with switched neutral pole  
In= 6, 10, 13, 15, 16, 20, 25, 32, 40A ; B-, C- & D- type  
IΔn= 30, 100, 300mA; Type-A & -AC  
Icn=10000A, Ics=7500A, Energy limited class 3  
IΔm= 4500A

A blue ink signature, likely of a representative of SAA Approvals Pty Ltd, is written over a horizontal line.


For and on Behalf of  
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 11-12-23 231868  
Page 2 of 2