



# CB TEST CERTIFICATE

Ref. Certificate No.

NL-29776

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

<b>Issued by:</b>	DEKRA Certification B.V.		
<b>Product:</b>	RCBO		
<b>Applicant:</b>	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
<b>Manufacturer:</b>	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
<b>Factory:</b>	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
<b>Rating and principal characteristics:</b>	1P + N $I_n = 6, 10, 16, 20, 25, 32 \text{ A}$ B and C - type $I_{\Delta n} = 0,03 \text{ A}$ for all $I_n$ Type AC, without time-delay $I_{cs} = I_{cn} = 6000 \text{ A}$ $U_e = 240 \text{ Vac}$ $I_{\Delta m} = 2000 \text{ A}$ Safety grid distance "a" = 45 mm Temperature limit: - 5 °C ... + 40 °C		
<b>Trade mark (if any):</b>	CHINT		
<b>Model/Type reference:</b>	NB3LE		
<b>Additional information:</b>			
<b>Sample of product tested to be in conformity with IEC:</b>	61009-1(ed.3);am1 61009-2-1(ed.1)		
<b>Test Report Ref. No:</b>	3305313.50		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.  
Meander 1051, 6825 MJ  
Arnhem  
The Netherlands

Signed by: F.S.Strikwerda



Date of issue: 2014-03-06