



Ref. Certif. No.

SE-106146**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.China. 325603

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Same as applicant

Note: When more than one factory, please report on page 2

105146Ratings and principal characteristics

Un= 230/240V~, 1P+N, 50/60Hz
In= 6, 10, 13, 16, 20, 25, 32, 40, 45, 50A; B- & C- Type
IΔn= 0,03A, Type-A, -AC
Icn= 10000A, Ics= 7500A

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

NB3LEU

Additional information (if necessary may also be reported on page 2)

Covered also AS/NZS 61009.1:2015,
BS EN 61009-1:2012+A1:2014+A2:2014+A11:2015+A12:2016,
EN 61009-1:2012+A1:2014+A2:2014+A11:2015+A12:2016.

A sample of the product was tested and found to be in conformity with

IEC 61009-1:2010+A1+A2
IEC 61009-2-2:1991

As shown in the Test Report Ref. No. which forms part of this Certificate

210500293SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Signature:

Leif Mattsson

Date: 12 October, 2021