



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2101366

Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBO's)

Type designation: NB3LEU

Certificate holder: Zhejiang Chint Electrics Co., Ltd.
No.1 Chint Road, Chint Industrial Zone, North Baixiang,
Yueqing, Zhejiang Province, P.R. China, 325603

**The product complies with
the standard(s):** EN 61009-1:2012+A1+A2+A11+A12

Date of expiry: 12 October, 2026

EU Directive information: According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:


Date: 12 October, 2021

Leif Mattsson

APPENDIX:

Reference No. SE-S-2101366

Technical Data:

Type designation NB3LEU
Rated voltage (V) 240~(230~)
Rated current (A) 6, 10, 13, 16, 20, 25, 32, 40, 45, 50
Rated Residual Operating Current (mA) 30
Frequency (Hz) 50/60
Poles No. 1P+N
Trademark 
Test Report 210500293SHA-001

Product information Type-AC & -A, B- & C-Type
Icn= 10000A, Ics= 7500A
IΔm= 3000A

Manufacturing Sites:

Zhejiang Chint Electrics Co., Ltd.
No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang
Province, P.R.China. 325603

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:


Leif Mattsson

Date: 12 October, 2021