


CERTIFICATE
FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2400848

Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)

Type designation: NB3LEU

Certificate holder: Zhejiang Chint Electrics Co., Ltd.
No.1 Chint Road, Chint Industrial Zone North Baixiang,
Yueqing, Zhejiang Province, P.R.China

**The product complies with
the standard(s):** EN 61009-1:2012+A1+A2+A11+A12+A13

Date of expiry: 22 August, 2029

EU Directive information: The product listed has been evaluated by a Third-Party Body and deemed to meet the listed harmonized standard(s). This Certificate can be used in support of a claim in meeting relevant EU legislation and mandatory Conformity Marking. And in accordance with EU law, the claim is the sole obligation of the Manufacturer/ Importer.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:




Date: 22 August, 2024

Anneli Averland Johansson

APPENDIX:

Reference No. SE-S-2400848

Technical Data:

Type designation	NB3LEU
Rated voltage (V)	230/240V~
Rated current (A)	6, 10, 13, 16, 20, 25, 32, 40, 45, 50A
Rated Residual Operating Current (mA):	30mA
Frequency (Hz)	50/60Hz
IP-Class	20
Pattern No.	1P+N
Trademark	
Test Report	2407B1919SHA-001
Product information	Type -A & -AC, B- & C- Type, Icn= 10000A, Ics= 7500A IΔm= 3000A, Ref. Temp. 30°C or 40°C.

Manufacturing Sites:

Zhejiang Chint Electric Co., Ltd.
No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
Zhejiang Province, P.R.China

The instructions for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:  **Date:** 22 August, 2024

Anneli Averland Johansson

Intertek