

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Residual current operated circuit-breakers with integral overcurrent protection (RCBOs)
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang China
Name and address of the manufacturer	Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang China
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	2P Ue: 230 / 240 Vac, 50 / 60 Hz In: 6, 10, 13, 16, 20, 25, 32 A, B and C type I Δ n: 30 mA Type A, without time-delay Ics = Icn = 6 kA, I Δ m = 3 kA The grid distance "a": 50 mm
Trademark (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	NB4LE
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 Additional information: Energy limiting class 3 according to EN 61009-1. Ambient air temperature: -25 °C to 40 °C (-25 °C was tested according to EN 61009-1).
A sample of the product was tested and found to be in conformity with	IEC 61009-1:2010, IEC 61009-1:2010/AMD1:2012, IEC 61009-1:2010/AMD2:2013, IEC 61009-2-2:1991 National differences: AU
As shown in the Test Report Ref. No. which forms part of this Certificate	3317931.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands