

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R. China 325603
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	See page 2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	NBH8LE-40H, NBH8LE-40
Additional information (if necessary may also be reported on page 2)	See page 2
A sample of the product was tested and found to be in conformity with	IEC 61009-1:2010+A1+A2 IEC 61009-2-2:1991
As shown in the Test Report Ref. No. which forms part of this Certificate	220302070SHA-002

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 05 May, 2022



Signature:



Henrik Wikström

Ratings and principal characteristics

Un= 230V~ or 240V~ or 110/125V~ (1P+N), 50/60Hz
In= 1, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40A; C-Type
IΔn= 10mA,30mA; Type-AC
NBH8LE-40H: Ics= Icn= 6000A
NBH8LE-40: Ics=Icn= 4500A

Additional information

This certificate replaces CB certificate SE-107715A1, dated 19 April 2022. A new certificate is issued due to a type error.

Date: 05 May, 2022

Signature:

