

Product Compliance Certificate



Certificate Number: 5014091S230006-01A

Certification is based on the type testing according to below named standards and production is monitored by an Initial and Annual Follow up Inspection Service.

Notice to Authorities:

This certificate indicates that a third party Accredited Body has tested and verified that the products listed comply with the relevant harmonized standards to directives listed on this certificate. The manufacturer may indicate compliance to said directive by signing a Declaration of Conformity to products identical to the tested samples.

In addition, annual factory inspection has been performed for further verification of compliance. Intertek requests all whom may be concerned to allow products entry into the European market without delay or prejudice. The applicant may rightfully use this certificate to mark their products with the ETL^{EU} mark identified above.

Intertek is a leading international provider of quality and safety services to a wide range of global and local industries. Intertek's laboratories are included in IECCE CB scheme as operational CBTL and hold several local accreditations.

For further information:
Email: ETL.EU@intertek.com
Website: www.intertek.com/ETLeu

Or Certification Body:
Intertek Testing Services Ltd.
Shanghai
West Area, 2nd Floor, No. 707,
Zhangyang Road, China
(Shanghai) Pilot Free Trade Zone,
Shanghai, P. R. China

Applicant

Zhejiang Chint Electrics Co., Ltd.
No 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang
P. R. China

Manufacturing Site

Zhejiang Chint Electrics Co., Ltd.
No 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang
P. R. China

Product Name

Earth leakage circuit-breakers

Trademark



Model Number(s)

NXBLE-63Y

Description

Details see attachment

Test Report No

2306A0286SHA-001

Standards/Directives

EN 60947-2: 2017+A1:2020; IEC 60947-2: 2016+A1:2019
SANS 60947-2: 2020; SANS 556-2-1: 2018; VC8035: 2016

Issued Date

August 14, 2023

Validity

August 13, 2028

Maximum 5 years or the validity limitation of the standards/directives used, whichever is sooner.

If the product is to be marketed in different European countries, it must be provided with a certified plug appropriate for each country. Safety related parts of the user instructions shall be written in a language acceptable to the country where the product is to be used.

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 2014/35/EU. Other EU directives may apply.

Gary Hu



This certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Certificate. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement. They are not for the purpose of production quality control and do not relieve the Client of their obligation in this respect.



Attachment to Certificate Number: 5014091S230006-01A

Type description:

$U_e = 240V\sim$ for 1P+N

$I_n = 63A$

$I_{cu} = I_{cs} = 4,5kA$

$I_{\Delta n} = 30mA$ type AC

$I_{\Delta m} = 2000A$

Cat. A, $I_i = 10I_n$, $U_{imp} = 4kV$, $U_i = 500V$, 50/60Hz