

RCC

(REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO
COLORFUL TRADING WESTERN CAPE cc

IN TERMS OF SANS 10142 CLAUSE 4.
ISSUED BY

National Regulator for Compulsory Specifications

PRODUCT: EARTH LEAKAGE CIRCUIT-BREAKERS (CHINT) NXBLE-63Y
 $U_e = 240V \sim (1P+N)$; $U_i = 500V$; $U_{imp} = 4kA$; $I_n = 63A$; $I_{\Delta n} = 30mA$; $I_{\Delta m} = 2000A$;
 $I_i = 10In$; $I_{nc} = 6kA$; $I_{cu} = 4,5kA$; 50/60Hz; IP20; type AC

Test Laboratory:

Intertek Testing Services Shanghai

In accordance to (Standards):

VC 8035:1987 + AMD:1990

SANS 556-2-1:2018


SANS 60947-2:2016 + A1:2019

Period of Validity

19/03/2024 to 19/03/2027

Test report no: 2306A0286SHA-001

RCC No: 2403040



NRCS - Electrotechnical General Manager.

DATE 25 MARCH 2024

