

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge Protective Device

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang
Yueqing 325603 Zhejiang
P.R. China

Name and address of the manufacturer

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang
Yueqing 325603 Zhejiang
P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

NOARK Electrics (Shanghai) Co., Ltd.
No. 3857 Sixian Road Songjiang District
Shanghai
P.R. China

Ratings and principal characteristics

Ucpv: 75V DC (-48V to RTN), 0V DC (RTN to PE);
Up: 0.6kV (-48V to RTN), 1.0kV (RTN to PE);
Iimp: 1) 6.25kA; In: 20kA; Imax: 40kA; Iscpv: 100A;
Test Class: 1) Class I + Class II, 2) Class II;
IP20; Indoor; One port

Trademark / Brand (if any)

CHINT (logo)

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

1) CU-I+II/F 6.25CZ, CU-I+II 6.25CZ
2) CU-II/F 40CZ, CU-II 40CZ

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 61643-31:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

CN24JEL4 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2024-06-27

Signature:



Wencai Zhang