Ref. Certif. No.

NL-82527

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Surge Protective Devices
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, 325603 Yueqing, Zhejiang, China
Name and address of the manufacturer	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, 325603 Yueqing, Zhejiang, China
Name and address of the factory *Note: When more than one factory, please report on page 2*	Noark Electrics (Shanghai) Co., Ltd. No. 3857, Sixian Road, Songjiang District, 201614 Shanghai China ☐ Additional information on page 2
Ratings and principal characteristics	Test class I/Type 1 and Test class II / Type 2; Isccr: 10 kA; IP20; L-N: Uc: 275 V~ / 385 V~, I_{imp}: 12,5 kA / 15 kA, I_n: 25 kA, Imax: 50 kA; Up:1,5 kV / 1,8 kV; N-PE: Uc: 255 V~, I_{imp}: 25 kA / 50 kA, In: 30 kA / 50 kA, Imax: 40 kA / 50 kA, Up:1,5 kV;
Trademark (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	NU5-I+II(/F) 12.5, NU5-I+II(/F) 15, NU5G-I+II(/F) 12.5, NU5G-I+II(/F) 15, NU5H-I+II(/F) 12.5, NU5H-I+II(/F) 15, NU5J-I+II(/F) 12.5, NU5J-I+II(/F) 15, NU5NE-I+II(/F) 12.5, NU5NE-I+II(/F) 15, NU5P-I+II(/F) 12.5 and NU5P-I+II(/F) 15 followed by XXX YYY, see pages 6 to 7 of test report 6125061.50 and 6125061.51 in detail Note: /F represents the remote signalling function offered
Additional information (if necessary may also be reported on page 2)	☐ Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61643-11:2011 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	6125061.50 and 6125061.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands

DEKRA

Date: 2022-08-04

Signature: Kate Xu