



Ref. Certif. No.

SE-106072

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnectors

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1 Chint Road, Chint Industrial Zone North Baixiang, Yueqing
Zhejiang Province, P.R.China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

See page 2

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

NH2-125

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

210702728SHA-001, -002, -003, -004

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden



Signature: *Quan Li*

Date: 08 October, 2021

Quan Li



Ref. Certif. No.

SE-106072

Ratings and principal characteristics

$U_e=230V(1P), 400V(2,3,4P), 50/60Hz$

$I_e=32, 63, 100, 125A, \text{Cat. AC-22A}$

$U_i=500V, U_{imp}=4kV$

$I_{cw}=12I_e/1s, I_{cm}=20I_e.$

NH2-125, rated $I_e=32A, 63A$ and $I_e=100A, 125A$ are not the same frame size

Date: 08 October, 2021

Signature: *Amelia*