



Ref. Certif. No.

**SE-105875M1****IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Switch-disconnectors

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.  
No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,  
Zhejiang Province, P.R.China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

$U_e = 230V \sim / 240V \sim (1P), 400V \sim / 415V \sim (2, 3, 4P)$   
 $I_e = 32, 40, 63, 80, 100, 125A$   
 $I_{cw} = 12I_e, 1s$   
 $I_{cm} = 20I_e; \text{Cat. AC-22A}$

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

NH4-125

Additional information (if necessary may also be reported on page 2)

This certificate replaces CB certificate SE-105875, dated 06 September 2021. A new certificate has been issued due to additional mounting bolt M5.

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020  
IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

210402354SHA-001, 210402354SHA-001 M1

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden

Signature:

  
Leif Mattsson

Date: 05 July, 2022