



Ref. Certif. No.

CN58692-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

AC Contactor

Name and address of the applicant

Zhejiang CHINT Electric Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electric Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang CHINT Electric Co., Ltd.
No.2, Changjiang Road, CHINT Intelligent Electric Appliance
Industrial Zone, North Baixiang, Yueqing, Zhejiang Province,
P.R.China

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NC8-06M□□/□□/□, NC8-09M□□/□□/□, NC8-12M□□/□□/□,
NC8-06M□□/□□/□N,
NC8-09M□□/□□/□N, NC8-12M□□/□□/□N;

Additional information (if necessary may also be reported on page 2)

The latest CB certificate No. is CN58692, dated
2022-12-15. The M1 certificate is to change parameters.

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

(2023)FQIIDQ-1024-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Nov.09,2023

Signature:

谢肇煦
Xie ZhaoXu

CB 0074581

