

RCC

(REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO
COLOURFUL TRADING WESTERN CAPE (Pty)Ltd

IN TERMS OF SANS 10142 CLAUSE 4.
ISSUED BY

National Regulator for Compulsory Specifications

PRODUCT: CONTACTOR (CHINT)
NCI/NXC Series

$U_e=690V$; $I_e=20$; 25; 32; 40; 45; 50; 60; 80; 95; 110; 125A; $U_i=1000V$; AC-1; AC-3; AC-3e; AC-4

Test Laboratory:
VDE Testing and Certification Institute.

In accordance to(Standards):
IEC 60947-4-1: 2018

Test Report No(s): 267593-TL3-1 to -8

RCC No: 2203017



NRCS Electro-Tech General Manager



Period of Validity

22/03/2022 to 22/03/2025

DATE 25/03/2022

RCC

(REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO
COLORFUL TRADING WESTERN CAPE cc

IN TERMS OF SANS 10142 CLAUSE 4.
ISSUED BY

National Regulator for Compulsory Specifications

PRODUCT: THERMAL OVERLOAD RELAY (CHINT)

NR2-11.5; $U_e = 380/400/415/660V_{ac}$; $U_i = 690V$; $U_{imp} = 6kV$;

$I_e = 0.1-0.16A, 0.16-0.25A, 0.25-0.4A, 0.4-0.63A, 0.63-1A, 1-1.6A, 1.25-2A, 1.6-2.5A, 2.5-4A, 4-6A, 5.5-8A, 7-10A, 9-13A, 50/60Hz$;

Test Laboratory:

DEKRA TESTING SERVICES ZHEJIANG

Test Report No: 3316366.50

RCC No: 2203016

In accordance to(Standards):

IEC 60947-4-1:2018

Period of Validity

22/03/2022 to 22/03/2025



NRCS - Electrotechnical General Manager.

DATE 25/03/2022



RCC

(REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO
COLORFUL TRADING WESTERN CAPE cc

IN TERMS OF SANS 10142 CLAUSE 4.
ISSUED BY

National Regulator for Compulsory Specifications

PRODUCT: SWITCH-DISCONNECTORS (CHINT)

*NH2-125; $U_e = 230V\sim(1P)$; $400V(2P, 3P, 4P)$ $U_i = 500V$; $I_e = 32, 63, 100, 125A$;
 $U_{imp} = 4kV$; $I_{cm} = 20I_e$; $I_{cw} = 12I_e/1s$; $50/60Hz$; $IP20$; Category AC-22A*

Test Laboratory:

INTERTEK TESTING SERVICES SHANGHAI

Test Report No: 210702728SHA-001

RCC No: 2203015

In accordance to(Standards):

IEC 60947-3:2020

Period of Validity

22/03/2022 to 22/03/2025



NRCS - Electrotechnical General Manager:

DATE 25/03/2022

