

**IEC****IECEE**

®

™

Ref. Certif. No.

CN64304

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Contactor For Capacitor Switching

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang CHINT Electrics Co., Ltd.  
No.2, Changjiang Road, CHINT Intelligent Electric Appliance  
Industrial Zone, North Baixiang, Yueqing , Zhejiang Province,  
P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NXCC-95\*\*,NXCC-115\*\*(\*\*=Type and number of auxiliary  
contacts);Additional information (if necessary may also be  
reported on page 2)A sample of the product was tested and found  
to be in conformity withIEC 60947-4-1:2018;IEC 60947-1:2007;IEC  
60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014As shown in the Test Report Ref. No. which  
forms part of this Certificate

00901-CB2023CQC-110757

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Dec.28,2023

Signature:

谢肇旭

Xie ZhaoXu



NXCC-95\*\*,NXCC-115\*\*(\*\*=Type and number of auxiliary contacts)

Ui:690V;

Uimp:6kV;

Ue:AC220V/230V,AC380V/400V,AC660V/690V;

NXCC-95\*\*:

Ith:95A;

AC-6b:Ue/Ie:AC220V/230V/91.9A,AC380V/400V/91.9A,AC660V/690V/91.9A;

Ue/Qe:AC220V/230V/35kvar,AC380V/400V/60.4kvar,AC660V/690V/105kvar;

NXCC-115\*\*:

Ith:115A;

AC-6b:Ue/Ie:AC220V/230V/105A,AC380V/400V/105A,AC660V/690V/105A;

Ue/Qe:AC220V/230V/40kvar,AC380V/400V/69.1kvar,AC660V/690V/120kvar;

Us:AC24V,AC36V,AC42V,AC48V,AC110V,AC120V,AC127V,AC200V,AC208V,AC220V,AC230V,

AC240V,AC277V,AC380V,AC400V,AC415V,

AC440V,AC460V,AC480V,AC500V,AC525V,AC600V,AC660V,50Hz,50/60Hz,60Hz;

3P;

IP10

Auxiliary contacts:(body)

2NO1NC,1NO2NC;

Ith:10A;

AC-15:Ue/Ie:AC220V/230V/2.7A,AC380V/400V/1.5A;

DC-13:Ue/Ie:DC220V/0.3A

Page 1 of 1

Additional information (if necessary)

Date:

Dec.28,2023

Signature:

谢肇煦

Xie ZhaoXu