



Ref. Certif. No.

HU-003210

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product	Electromechanical contactor for household and similar purposes
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road,Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang, P.R. China
Name and address of the manufacturer	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road,Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang, P.R. China
Name and address of the factory	YUEQING BOOMGI ELECTRIC CO.,LTD 168#, XINGWANG ROAD, HOXIZHANG VILLAGE, BEIBAIXIANG TOWN YUEQING, 325603 Zhejiang, P.R. China
Ratings and principal characteristics	Ue=AC250V(1P,2P)/AC400V(3P,4P), 50/60Hz; Ui=500V; Uimp=4kV; AC-7a: Ie=16A(NCH8-16M), 20A(NCH8-20M), 25A(NCH8-25M); AC-7b: Ie=6A(NCH8-16M), 7A(NCH8-20M), 9A(NCH8-25M); Ith=25A; Us=AC 24/110/220-240V, 50/60Hz
Trademark (if any)	Chint
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	NCH8-16M , NCH8-20M , NCH8-25M
Additional information (if necessary may also be reported on page 2)	Detailed information refer to test report CN20USUR 001.
A sample of the product was tested and found to be in conformity with	IEC 61095:2009
As shown in the Test Report Ref. No. which forms part of this Certificate	CN20USUR 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division  
H-1143 Budapest, Gizella út 51-57., Hungary  
Web:www.tuv.com

Date: 2020-11-13

Signature:

Kenny Shi