

NP2 Series Pushbutton

User Instruction



- Only professional technicians are allowed for installation and maintenance.
- [2] Installation in any damp, condensed-phase environment with inflammable and explosive gas is forbidden.
- 3 When the product is being installed or maintained, the power must be switched off.
- 4 You are prohibited from touching the conductive part when the product is operating.



This is the general warning sign. It is used to alert the user to potential hazards. All safety messages that follow this sign shall be obeyed to avoid possible harm.

1 Use Purpose

NP2 series pushbutton is used in industrial control circuit with frequency of AC 50Hz or 60Hz, rated operating voltage up to 415V and DC operating voltage up to 250V. It is used to control electromagnetic starter, contactor, relay and other electrical circuits. Pushbutton with indicator is also suitable for applications that need signal light indication.

2 Main Technical Parameters

Table 1 Main technical parameters

Environmental conditions	Ambient temp. (°C)	The normal working temperature is -5 °C ~+40 °C , and the extreme working temperature is -30 °C ~+70 °C, average temperature should not exceed +35 °C within 24h
	Hot and humid atmospheric conditions	Relative humidity should not exceed 50% at +40°C; up to 90% at +20°C;
E E	Altitude	No influence below 2000m
	Pollution class/ installation category	Class 3/II
	Rated operating voltage U _e (V)	AC-15: 415/380/240/220; DC-13: 250/220/125/110
	Rated operating current I _e (A)	AC-15: 1.9/2.5/3/4.5; DC-13: 0.27/0.3/0.55/0.6
meters	Rated insulation voltage U _i (V)	690
Technical parameters	Conventional thermal current Ith(A)	10
echnica	Rated impulse withstand voltage U _{imp} (kV)	6
-	Head protection class	IP40(Φ22、Φ30), IP65 (Φ22)
	Rated operating voltage of button with indicator U _e (V)	See product body for details

	Table 1 (Continued)
Rated operating current of button with indicator I _e (mA)	See product body for details
Model of matching fuse and Rated current of fuse(A)	gG and 16
Conditional short-circuit	1000

Installation

1) See Figure 1 and Table 2 for minimum distance between the center of mounting holes. See Table 3 for installation dimensions of button control box.



Figure 1 Minimum distance between center of mounting hole

Table 2 Minimum distance between center of mounting hole

Туре		Direction A	Direction B	
		Φ22 installation dimensions	Φ22 installation dimensions	
Flat type, knob type, handle type, key type, with indicator, signal light		30	50	
Mushroom type,	Ф30 Ф40	50	50	
self- locking type	Ф60	65	65	
Dual head button		30	50	
Dual head button w	ith indicator	30	60	

Table 3 Installation dimensions of button control box

Unit:mm

Model	Cable hole size	Installation dimensions
NP2-B1 🗆 🗆 🗆 🗆	Ф20	2-Φ4.3, center to center distance 54
NP2-B2□□□□	Ф20	2-Φ4.3, center to center distance 54×68
NP2-B3 🗆 🗆 🗆 🗆	Ф20	2-Φ4.3, center to center distance 54×98

2) See Figure 2 and Figure 3 and Table 4 and Table 5 for product overall dimensions.




Table 4 Overall dimensions of different types of pushbuttons

				Unit:mm
Model	A(max)	B(max)	C(max)	D(max)
NP2-BA(Z)□□ / NP2-EA(Z)□□	55/55	12/12	31/31	41/43
NP2-BC□□ / NP2-EC□□	75/75	32/33	41/41	41/43
NP2-BS5 DD / NP2-ES5 DD	75/75	32/33	41/41	41/43

Table 4 Overall dimensions of different types of pushbuttons

Model	A(max)	B(max)	C(max)	D(max)
NP2-BT 🗆 / NP2-BX 🗆	74/74	31/31	41/61	41/61
NP2-BD 🗆 / NP2-ED	70/70	26/27	31/31	41/43
NP2-BJ 🗆 / NP2-EJ 🗆	70/70	26/27	34/33	46/48
NP2-BG □□ / NP2-EG□□	86(63)/86(63)	43(20)/43(21)	31/31	41/43
NP2-BL8 🗆 🗆 / NP2-EL8 🗆 🗆	59/58	15/16	31/31	42/43
NP2-BW3(Z)□6□/ NP2-EW3(Z)□6□	81/81	19/20	31/31	41/43
NP2-BW3□8□/ NP2-EW3□8□	86/85	19/20	31/31	41/43
NP2-BW8□6□/ NP2-EW8□6□	78/78	16/16	31/31	55/56
NP2-BV6□/ NP2-EV6□	51/53	14/17	31/31	41/43
NP2-BV8□ / NP2-EV8□	56/58	14/17	31/31	41/43

Note: For NP2-BG□□/ NP2-EG□□ B, the dimension outside the brackets is height with key, the dimension inside the brackets is height without key.

Table 5 Overall dimensions of pushbutton control box

Unit:mm

Model	Length	Width	Height	Remarks
NP2-B10000	70	70	63	Height for empty case 52
NP2-B2	105	70	63	Height for empty case 52
NP2-B3	135	70	63	Height for empty case 52

3) See Table 6 for wire selection and tightening torque

Terminal tightening torque N•m	Wire (Hard) mm²	Wire (Soft) mm²	Remarks
	8mm	8mm	Use hard wire or soft wire for a single connection. One terminal can connect up to two conductors with same sectional area and type:
M3.5 0.8~1.2			2) Wire strip length: 8mm.

4) Installation procedure and method

① When installing metal head type button, insert the operation head into the mounting hole from the front of the panel, then screw it into the base from the back of the panel. Tighten the fixing screws at both ends evenly (as shown in Figure 4). Do not overtighten the screws, the torque should not exceed 0.25N·m. If the button is jammed after installation, adjust the two fixing screws on the base and make sure they have the same fichtness.

@Before installing plastic head type button, remove the base first (insert a screwdriver into the hole on the base and pry it up, as shown in Figure 5). Tighten the nuts with a torque of 1.2N·m~1.8N·m.

5) Selector Switches operation position table

Table 7 Selector switches operation position

Selector Switches	Contacts	Positions		
Selector Switches		1	2	3
2. Paraliticana			-	×
2-Positions		×	-	
3-Positions		×		
5-POSITIONS		×	×	
Note: v" indicates make-contact blank indicates break-contact " - " ingicates				

Note:" x" indicates make-contact, blank indicates break-contact," -" ineicates without position.

4 Maintenance

Tighten the terminals of the button on a regular basis to make sure the wires are connected securely.

Tighten the fixing screws of the button on a regular basis.

Disconnect the power before regular maintenance to ensure personal safety.

It is recommended to conduct maintenance once a month.

See Table 8 for Analysis and Troubleshooting of Faults.



Figure 4 Assembly diagram of metal head type base



Figure 5 Disassembly diagram of plastic head type base

Table 8 Analysis and Troubleshooting of Faults

· , , , , , ,			
Symptons	Cause analysis	Troubleshooting method and precautions	
The button cannot be operated smoothly	like dust or greaty dist	Remove the foreign objects like dust or greasy dirt on the button operation head or pushing rod of contact assembly, make sure the environment is dry and clean after installing the panel. Use proper lubricant at the moving surface of the parts if necessary.	
bead is not bright enough or is	operating voltage, or	Check if the input voltage complies with the rated operating voltage; check if there is any short circuit or disconnection in the circuit.	

5 Environmental Protection

In order to protect the environment, the product or product parts should be disposed of according to the industrial waste treatment process, or be sent to the recycling station for assortment, dismantling and recycling according to local regulations.

CHNT

QC PASS

NP2 Series Pushbutton IEC/EN 60947-5-1

Check 31

Test date: Please see The packing

ZHEJIANG CHINT ELECTRICS CO., LTD.



NP2 Series Pushbutton User Instruction

Zhejiang Chint Electrics Co., Ltd.

Add: No.1, CHINT Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang 325603, P.R.China E-mail: global-sales@chint.com

Website: http://en.chint.com





