



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE210307007198

Product

Soft Starter

Applicant

Zhejiang CHINT Electric Co., Ltd.

No.1 CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model

NJR5-800/ZX2,NJR5-800/ZX3,NJR5-800/ZX4,NJR5-800/ZX5,NJR5-800/ZX6,NJR5-900/ZX2,NJR5-900/ZX3,NJR5-900/ZX4,NJR5-900/ZX5,NJR5-900/ZX6,NJR5-1000/ZX2,NJR5-1000/ZX3,NJR5-1000/ZX4,NJR5-1000/ZX5,NJR5-1000/ZX6;

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2020CQC0307-011501, the submitted sample(s) of the above item complies with:

EN 60947-4-2:2012

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Apr.19,2021

Valid until: Apr.19,2024

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE

CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE210307007198

NJR5-800/ZX2,NJR5-800/ZX3,NJR5-800/ZX4,NJR5-800/ZX5,NJR5-800/ZX6,NJR5-900/ZX2,NJR5-900/ZX3,NJR5-900/ZX4,NJR5-900/ZX5,NJR5-900/ZX6,NJR5-1000/ZX2,NJR5-1000/ZX3,NJR5-1000/ZX4,NJR5-1000/ZX5,NJR5-1000/ZX6;

Uimp:8kV;

Ui: 660V(NJR5-800/ZX2,NJR5-900/ZX2,NJR5-1000/ZX2,

NJR5-800/ZX3,NJR5-900/ZX3,NJR5-1000/ZX3);

1000V(NJR5-800/ZX4,NJR5-900/ZX4,NJR5-1000/ZX4,NJR5-800/ZX5,NJR5-900/ZX5,NJR5-1000/ZX5,NJR5-800/ZX6,NJR5-900/ZX6,NJR5-1000/ZX6);

Ith: 720A(NJR5-800/ZX2,NJR5-800/ZX3,NJR5-800/ZX4,NJR5-800/ZX5,NJR5-800/ZX6);

810A(NJR5-900/ZX2,NJR5-900/ZX3,NJR5-900/ZX4,NJR5-900/ZX5,NJR5-900/ZX6);

900A(NJR5-1000/ZX2,NJR5-1000/ZX3,NJR5-1000/ZX4,NJR5-1000/ZX5,NJR5-1000/ZX6);

Ue: AC220V(NJR5-800/ZX2,NJR5-900/ZX2,NJR5-1000/ZX2),

AC380V(NJR5-800/ZX3,NJR5-900/ZX3,NJR5-1000/ZX3),

AC460V(NJR5-800/ZX4,NJR5-900/ZX4,NJR5-1000/ZX4),

AC575V(NJR5-800/ZX5,NJR5-900/ZX5,NJR5-1000/ZX5),

AC690V(NJR5-800/ZX6,NJR5-900/ZX6,NJR5-1000/ZX6);

Ie: 720A(NJR5-800/ZX2,NJR5-800/ZX3,NJR5-800/ZX4,NJR5-800/ZX5,NJR5-800/ZX6);

810A(NJR5-900/ZX2,NJR5-900/ZX3,NJR5-900/ZX4,NJR5-900/ZX5,NJR5-900/ZX6);

900A(NJR5-1000/ZX2,NJR5-1000/ZX3,NJR5-1000/ZX4,NJR5-1000/ZX5,NJR5-1000/ZX6);

Pe: 200kW(NJR5-800/ZX2),250kW(NJR5-900/ZX2, NJR5-1000/ZX2), 400kW(NJR5-800/ZX3);

450kW(NJR5-800/ZX4,NJR5-900/ZX3),500kW(NJR5-1000/ZX3);560kW(NJR5-900/ZX4,

NJR5-1000/ZX4,NJR5-800/ZX5),630kW(NJR5-900/ZX5),710kW(NJR5-800/ZX6),

800kW(NJR5-900/ZX6, NJR5-1000/ZX5), 900kW(NJR5-1000/ZX6);

AC-53a;

3P;

IP20

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>