

# CQC CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE240307008984

<b>Product</b>	Soft Starter
<b>Applicant</b>	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
<b>Type/Model</b>	NJRP5-710/D6,NJRP5-800/D6,NJRP5-900/D6,NJRP5-1000/D6, NJRP5-710/D4,NJRP5-800/D4,NJRP5-900/D4,NJRP5-1000/D4;
<b>Technical data</b>	See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2024CQC0307-014659, the submitted sample(s) of the above item complies with:

**EN IEC 60947-4-2:2023**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

**Valid from: Jun.26,2024**

**Valid until: May.19,2027**

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE



# CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 3

Certificate No.: CE240307008984

NJRP5-710/D6,NJRP5-800/D6,NJRP5-900/D6,NJRP5-1000/D6,  
NJRP5-710/D4,NJRP5-800/D4,NJRP5-900/D4,NJRP5-1000/D4

Uimp: 8kV;

Ui: See Table 1;

Ith: See Table 1;

Ue: See Table 1;

Ie: See Table 1;

Pe: See Table 1;

AC-53b;

Pole:3P;

IP20

Table 1

Type	Pe	Ith	Ie	Ue	Ui
NJRP5-710/D6	200kW (Ue=AC220V)	634A	634A	AC200V-AC690V	1000V
	355kW (Ue=AC380V)				
	400kW (Ue=AC460V)				
	500kW (Ue=AC575V)				
	630kW (Ue=AC690V)				
NJRP5-800/D6	200kW (Ue=AC220V)	720A	720A		
	400kW (Ue=AC380V)				
	450kW (Ue=AC460V)				
	560kW (Ue=AC575V)				
	710kW (Ue=AC690V)				



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

# CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 3

Certificate No.: CE240307008984

NJRP5-900/D6	250kW (Ue=AC220V)	810A	810A		
	450kW (Ue=AC380V)				
	560kW (Ue=AC460V)				
	630kW (Ue=AC575V)				
	800kW (Ue=AC690V)				
NJRP5-1000/D6	250kW (Ue=AC220V)	900A	900A		
	500kW (Ue=AC380V)				
	560kW (Ue=AC460V)				
	800kW (Ue=AC575V)				
	900kW (Ue=AC690V)				

Type	Pe	Ith	Ie	Ue	Ui
NJRP5-710/D4	200kW (Ue=AC220V)	634A	634A	AC200V-AC415V	660V
	315kW (Ue=AC380V)				
	315kW (Ue=AC415V)				
NJRP5-800/D4	200kW (Ue=AC220V)	720A	720A		
	400kW (Ue=AC380V)				
	400kW (Ue=AC415V)				
NJRP5-900/D4	250kW (Ue=AC220V)	810A	810A		
	450kW (Ue=AC380V)				
	450kW (Ue=AC415V)				



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE




# CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Appendix

Page 3 of 3

Certificate No.: CE240307008984

NJRP5-1000/D4	250kW (Ue=AC220V)	900A	900A		
	500kW (Ue=AC380V)				
	500kW (Ue=AC415V)				



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE