

IEC**IECEE**

®

™

Ref. Certif. No.

CN60079

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Switch-disconnector

Name and address of the applicant

NOARK Electrics (Shanghai) Co., Ltd.
No.3857 Sixian Road, Songjiang District, Shanghai,
P.R.China

Name and address of the manufacturer

NOARK Electrics (Shanghai) Co., Ltd.
No.3857 Sixian Road, Songjiang District, Shanghai,
P.R.China

Name and address of the factory

*Note: When more than one factory, please report on page 2*NOARK Electrics (Shanghai) Co., Ltd.
No.3857 Sixian Road, Songjiang District, Shanghai,
P.R.China

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

NOARK

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

Ex9ASD-2500DC,ExASD E 2500DC;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020;IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

03601-A-23CB0054-S

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jun.07,2023

Signature:

谢肇旭

Xie ZhaoXu

**CB 0073754**

Ex9ASD-2500DC, ExASD E 2500DC

Ui:1600V, Uimp:12kV; lth=Ie,

Ie:630A,800A,1000A,,1250A,1600A,2000A,2500A

Ue:DC750V(3P appearance), DC1000V(4P appearance) ,DC1500V(4P appearance);

Icw:45kA/1s;


Icm(peakvalue):DC750V:80kA, DC1000V:52.5kA, DC1500V :45kA;

Utilization category:DC-22A,DC-23A,DC-PV2; Degree of protection: IP30(Operative surface).


Auxiliary contact(1NO1NC~12NO12NC):Ui:500V;Uimp:6kV;lth:6A;

AC-15:Ue/Ie:AC415/240V/2A; DC-13:Ue/Ie:DC110V/0.8A, DC220V/0.3A


DC connection mode:




A型接线方式
A connected type



B型接线方式
B connected type



C型接线方式
C connected type



D型接线方式
D connected type

Additional information (if necessary)

Date: Jun.07,2023

Signature: 
Xie ZhaoXu