



Product Service

# Attestation of Conformity

No. N8A 075006 0090 Rev. 01

**Holder of Attestation:** **NOARK Electrics (Shanghai) Co., Ltd.**

No.3857 Sixian Road, Songjiang District  
201614 Shanghai  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Switches**  
**Switch-disconnectors**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704102245904-01

**Date,** 2023-06-14

( Jie Zhu )

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®



Product Service

# Attestation of Conformity

No. N8A 075006 0090 Rev. 01

**Model(s):** Ex9ASD-2500DC, ExASD E 2500DC

## Parameters:

Rated insulation voltage $U_i$ :	1600V
Rated impulse withstand voltage $U_{imp}$ :	12kV
Rated operational voltage $U_e$ :	DC750V (3P appearance), DC1000V, DC1500V (4P appearance)
Rated operational current $I_e$ :	630A, 800A, 1000A, 1250A, 1600A, 2000A, 2500A
Conventional free air thermal current $I_{th}$ :	Same as $I_e$
Utilization category:	DC-22A, DC-23A, DC-PV2
Rated short-time withstand current $I_{cw}$ :	45kA, 1s
Rated short-circuit making capacity $I_{cm}$ :	80kA at DC750V, 52.5kA at DC1000V, 45kA at DC1500V
Number of poles:	3P appearance, 4P appearance
Degree of protection:	IP30 (after installation)
Information of auxiliary contacts in accordance with EN 60947-5-1:2017:	$U_i$ : 500V, $U_{imp}$ : 6kV $I_{th}$ : 6A Utilization category: AC-15, DC-13 $U_e$ : AC415/240V, DC110V, DC220V $I_e$ : 2A for AC415/240V, AC-15 0.8A for DC110V, DC-13 0.3A for DC220V, DC-13 Contact form: 1NO1NC to 12NO12NC

**Tested according to:** EN IEC 60947-3:2021  
EN IEC 60947-1:2021

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®