



Ref. Certif. No.

CN55336

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Air circuit breaker

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Wenzhou CHINT Electrics Technology Co., Ltd.
No.1318, Binhai No.2 Avenue, Economic and Technical
Development Zone, Wenzhou City, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp:12kV;Ui:1000V;Ue: AC400V, AC690V;In:200A, 400A, 630A, 800A, 1000A; Over-current Release Type: Electronic; Ics:Ics=30kA(AC400V); Ics=20kA(AC690V); Icu:Icu=42kA(AC400V); Icu:25kA(AC690V); Icw:Icw=30kA/1s(AC400V); Icw=20kA/1s(AC690V); Selectivity Category:B; Number of poles:3P, 4P; Suitability for isolation;Rated Frequency: 50/60 Hz;Auxiliary Circuits:Ith:6A;Ue/Ie:AC-15:AC400V/0.25A, AC230V/1.3A;DC-13:DC220V/0.27, DC110V/0.55A;4N 04NC,6NO6NC

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NA1-1000X

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016/AMD1:2019, IEC 60947-2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-097277

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.23,2021

Signature:

谢肇煦

Xie ZhaoXu



CB 0065111