



Ref. Certif. No.

CN55337

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Air Circuit Breaker

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Wenzhou CHINT Electrics Technology Co., Ltd.  
No.1318, Binhai No.2 Avenue, Economic and Technical  
Development Zone, Wenzhou City, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp: 12kV; Ui: 1000V; Ue: AC400V, AC415V, AC690V; In: 2000A, 2500A, 3200A; Over-current release:  
Electronic; NA1-3200X: AC400V :Icu=80kA, Ics=65kA, Icw=65kA/1s, Icw=45kA/3s; AC415V :Icu=65kA, Ics=65kA,  
Icw=50kA/1s, Icw=45kA/3s; AC690V :Icu=65kA, Ics=65kA, Icw=50kA/1s ; NA1-3200XN: AC400V :Icu=65kA, Ics=65kA,  
Icw=65kA/1s, Icw=45kA/3s; AC415V :Icu=50kA, Ics=50kA, Icw=50kA/1s, Icw=45kA/3s; AC690V :Icu=50kA, Ics=50kA,  
Icw=50kA/1s; Selectivity category: B, 3P, 4P; Suitability for isolation; Rated frequency: 50/60Hz; Auxiliary  
contact: 4NO/4NC, 6NO/6NC; Ufr: 415V; Ith: 6A; Ue/Ie: AC-15: AC400V/0.75A, AC230V/1.3A; DC-13: DC220V/0.27A,  
DC110V/0.55A

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NA1-3200X, NA1-3200XN

Additional information (if necessary may also be  
reported on page 2)A sample of the product was tested and found  
to be in conformity with

IEC 60947-2:2016/AMD1:2019; IEC 60947-2:2016

As shown in the Test Report Ref. No. which  
forms part of this Certificate

00901-CB2021CQC-097460

This CB Test Certificate is issued by the National Certification Body

## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.23,2021

Signature:

谢肇煦  
Xie ZhaoXu

CB 0065122