

IEC

IECEE



TM

Ref. Certif. No.

CN58292

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Switch-disconnectors

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Wenzhou CHINT Electrics Technology Co., Ltd.  
No.1318, Binhai No.2 Avenue, Economic and Technical  
Development Zone, Wenzhou City, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp:8kV;Ui:1000V;Ith:4000A;Ue:AC400V;Ie:2000A,2500A,  
2900A,3200A,3600A,4000A;  
Icw:80kA/1s;Icm(peak):176kA;Utilization  
category:AC-21A;3P;50Hz;IP20(only form front side);  
Auxiliary  
contact:AX-12;4NO4NC,6NO6NC;Ith:6A;DC-13;Ue/Ie:DC110  
V/0.55A,DC220V/0.27A;  
AC-15;Ue/Ie:AC230V/1.3A,AC400V/0.75A.

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

N/A

Additional information (if necessary may also be  
reported on page 2)

NH1-4000;

A sample of the product was tested and found  
to be in conformity with

IEC 60947-1:2020;IEC 60947-3:2020

As shown in the Test Report Ref. No. which  
forms part of this Certificate

00901-CB2022CQC-102880

This CB Test Certificate is issued by the National Certification Body

## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date:

Oct.31,2022

Signature:

谢肇煦

Xie ZhaoXu



CB 0069817