CERTIFICATE

Issued to: Applicant: Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang, China

Licensee:

Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang, China

Product	:	Air Circuit Breaker
Trade name(s)	:	CHINT
Type(s)/model(s)	:	NA1-1000X

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard(s) IEC 60947-2:2016, IEC 60947-2:2016/A1:2019, EN 60947-2:2017, EN 60947-2:2017/A1:2020, IEC 60947-5-1:2016 and EN 60947-5-1:2017
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 2032236

DEKRA hereby grants the right to use the KEMA-KEUR certification mark

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 17 January 2023 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 33-126782

DEKRA Certification B.V.

B.T.M. Holtus Managing Director

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL

H.R.M. Barends Certification Manager



DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands T +31 88 96 83000 F +31 88 96 83100 www.dekra-product-safety.com Company registration 09085396



SPECIFICATION OF THE CERTIFIED PRODUCT

Product data	
Product	: Air Circuit Breaker
Trade name(s)	: CHINT
Type(s)/model(s)	: NA1-1000X
Number of poles	: 3 P and 4P (N pole without overcurrent protection)
	: 400 Vac / 690 Vac
Rated operational voltage (Ue)	
Rated insulation voltage (Ui)	: 1000 V for main circuit
Detections de suitlester du alterre	400 V for control circuits and auxiliary circuits
Rated impulse withstand voltage	: 12 kV for main circuit
(Uimp)	4 kV for control circuits and auxiliary circuits
Rated current (In)	: 200 A, 400 A, 630 A, 800 A, 1000 A
Rated operational current (le)	: (0,4 - 1,0) x ln
Conventional thermal current (Ith)	: Equal to In
Current rating for four-pole circuit-	: Equal to 50% In
breakers	
Rated frequency	: 50 / 60 Hz
Rated ultimate short-circuit breaking	: 42 kA at 400 Vac, 25 kA at 690 Vac
capacity (Icu)	
Rated service short-circuit breaking	: 30 kA at 400 Vac, 20 kA at 690 Vac
capacity (Ics)	
Rated short-time withstand current	: 30 kA / 1s at 400 Vac, 20 kA / 1s at 690 Vac
(Icw)	
Suitable for isolation	: Suitable
Selectivity category	: В
Safety distance (screen-circuit	: All sides: 0 mm
breaker)	
Method of mounting	: Fixed or Withdrawable
EMC environment	: A
Reference temperature	: Independent
Shunt release	: AC: 400 V, 50 / 60 Hz
Under-voltage release	: AC: 400 V, 50 / 60 Hz
Closing coil	: AC: 400 V, 50 / 60 Hz
Stored energy motor	: AC: 400 V, 50 / 60 Hz
Auxiliary circuits	: Utilization category:
Auxiliary circuits	
	AC-15: 1,3 A at 230 Vac, 0,25 at 400 Vac, 50 / 60 Hz
	DC-13: 0,55 A at 110 Vdc, 0,27 A at 220 Vdc
	number and kind of contact elements: 4 NO and 4 NC
	rated conditional short-circuit current: 1 kA
	conventional free air thermal current (Ith): 6 A
	kind of protective device: fuse, RL6-25/6, gG, 6 A, 500 V, 7,5 kA
Line/load terminal	: Immaterial
Connection	Prepared copper conductor with cable lug for 200 A to 800 A
	Copper busbar for 1000 A
Rated tightening torque for terminals	: 14 Nm
Type of elecronic release	: NST1-D
Inverse time delay release	: Ir (inverse time delay tripping setting):
	(0,4 - 1,0) x In, in step of 1 A
Time setting of the inverse time	: tr (inverse time delay tripping setting):
delay release	15 s, 30 s, 60 s, 120 s, 240 s, 480 s with tolerance of ± 10% (at
	1,5 lr)
	Trip time at 2 Ir:
	Set at 15 s: 8,4 s, with tolerance of \pm 10%,
	Set at 480 s: 270 s , with tolerance of ± 10%



ANNEX TO KEMA-KEUR CERTIFICATE 33-126782

page 2 of 3

Short time delay release	 Isd (short time delay tripping setting): (1,5 - 15) x Ir, in step of 1 A, if Isd < 10 kA, in step of 0,01 kA, if Isd ≥10 kA
Time setting	 tsd (short time delay tripping setting): 0,1 s, 0,2 s, with tolerance of ± 40 ms, 0,3 s, 0,4 s, with tolerance of ± 15%
	Non-tripping duration: Set at 0,1 s: 0,05 s,
	Set at 0,4 s: 0,33 s
Instantaneous release	: li (instantaneous tripping setting): (1,5 - 20) x ln,
	in step of 1 A, if li < 10 kA,
	in step of 0,01 kA, if li ≥10 kA
Ground fault release	: Ig: (0,2 - 0,8) x In, in step of 1 A (with minimum current setting 100 A, if In = 200 A, 400 A)
Time setting of ground fault release	: tg: 0,1 s, 0,2 s, with tolerance of \pm 40 ms 0,3 s, 0,4 s, with tolerance of \pm 15%
Making current release	: 6,3 kA (200 A - 400 A), 12,6 kA (400 A - 1000 A)

TESTS

Test requirements

IEC 60947-2:2016 IEC 60947-2:2016/A1:2019 EN 60947-2:2017 EN 60947-2:2017/A1:2020 IEC 60947-5-1:2016 EN 60947-5-1:2017

Test result

The test results are laid down in DEKRA test file 332631600.

Additional information

Nomenclature breakdown:

NA1-1000X/4

a b c d

a = Model name: NA1 b = Frame size: 1000 c = Electronic release: X means NST1-D d = pole numbers: '3' means 3P ACBs, '4' means 4P ACBs

The referred test reports are 3326316.50, 3326316.51, 3311812.50, 3307984.50, 3300977.50, W0808013.50 and W0808013.52.

This certificate replaces certificate No. 33-101068 which we hereby declare invalid.

Conclusion

The examination proved that all requirements were met.



ANNEX TO KEMA-KEUR CERTIFICATE 33-126782

page 3 of 3

Factory location

Zhejiang Chint Electrics Co., Ltd. No. 1318, Binhai No. 2 Avenue, Economic and Technical Development Zone, 325025 Wenzhou Zhejiang, China