

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Air Circuit-breaker

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Wenzhou CHINT Electrics Technology Co., Ltd.

No.1318, Binhai No.2 Avenue, Economic and Technical Development Zone, Wenzhou City, Zhejiang Province, P.R. China

See the Appendix

CHINT

N/A

NA1-6300,NA1P-6300,NA1-6300X,NA1H-6300;

IEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th Edition)

00901-CB2021CQC-097348


This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86-10-83886666 Fax: +86-10-83886282 website: http://www.cqc.com.cn

Date: Jun.13,2023

Signature:









NA1-6300, NA1P-6300, NA1-6300X, NA1H-6300;

Uimp:12kV; Ui:1000V;

Ue: AC400V,AC690V; In: 4000A,5000A,6300A;

Type of over-current release: Electronic;

AC400V:lcs=100kA,lcu=120kA;lcw=100kA/1s;

AC690V:lcs=75kA,lcu=85kA;lcw=75kA/1s;

Selectivity category:B;

Number of poles: 3P(4000A,5000A,6300A),4P(4000A,5000A);

Applicable for isolation;

Auxiliary contacts: 4NO4NC, 6NO6NC:

Ith: 6A;

AC-15: Ue/le: AC400V/0.75A,AC230V/1.3A; DC-13: Ue/le: DC220V/0.27A,DC110V/0.55A.

Page 1 of 1

Additional information (if necessary)

Date:

Jun.13,2023

新擎煦 Signature:

Xie ZhaoXu

Tel: +86-10-83886666 Fax: +86-10-83886282

website http://www.cqc.com.cn