

IEC**IECEE**

®

™

Ref. Certif. No.

CN55338-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Air Circuit Breaker

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Wenzhou CHINT Electrics Technology Co., Ltd.
No.1318, Binhai No.2 Avenue, Economic and Technical
Development Zone, Wenzhou City, Zhejiang Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NA1-2000X, NA1-2000XN, NA1-2000XH;

Additional information (if necessary may also be reported on page 2)

Original CB certificate No. is CN55338, dated 2021-11-23. The issuance of the M1 certificate is to change parameters.

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016/AMD1:2019; IEC 60947-2:2016(5th Edition); IEC 60947-1:2007; IEC 60947-1:2007/AMD1:2010; IEC 60947-1:2007/AMD2:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-097461-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jan.30,2024

Signature:

谢肇旭

Xie ZhaoXu



NA1-2000X, NA1-2000XN, NA1-2000XH

Uimp: 12kV;

Ui: 1000V;

Ue: AC400V, AC415V, AC480/500V, AC690V;

In: 630A, 800A, 1000A, 1250A, 1600A, 2000A;

Over-current release: Electronic;

NA1-2000X:

AC400V :Icu=80kA, Ics=65kA, Icw=50kA /1s, Icw=42kA /3s;

AC415V :Icu=50kA, Ics=50kA, Icw=50kA /1s, Icw=42kA /3s;

AC480/500V:Icu=50kA, Ics=50kA, Icw=50kA /1s;

AC690V :Icu=50kA, Ics=50kA, Icw=50kA /1s;

NA1-2000XN:

AC400V :Icu=50kA, Ics=50kA, Icw=50kA /1s, Icw=42kA /3s;

AC415V :Icu=40kA, Ics=40kA, Icw=40kA /1s, Icw=42kA /3s;

AC690V :Icu=40kA, Ics=40kA, Icw=40kA /1s;

NA1-2000XH:

AC400V :Icu=65kA, Ics=65kA, Icw=50kA /1s, Icw=42kA /3s;

AC415V :Icu=50kA, Ics=40kA, Icw=40kA /1s, Icw=42kA /3s;

AC690V :Icu=50kA, Ics=40kA, Icw=40kA /1s;

Selectivity category:B;

3P,4P;

Suitability for isolation;

Rated frequency:50/60Hz;

Auxiliary contact:

4NO4NC,6NO6NC;

Ui: 415V;

Ith: 6A;

Ue/Ie: AC-15: AC400V/0.75A, AC230V/1.3A;

DC-13: DC220V/0.27A, DC110V/0.55A

Page 1 of 1

Additional information (if necessary)

Date:

Jan.30,2024

Signature:

谢肇煦

Xie ZhaoXu