



Ref. Certif. No.

CN45047

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product
Produit

Air Circuit Breaker

Name and address of the applicant
Nom et adresse du demandeur

Zhejiang CHINT Electric Co., Ltd.
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer
Nom et adresse du fabricant

Zhejiang CHINT Electric Co., Ltd.
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory
Nome et adresse de l'usine

NOARK Electrics (Shanghai) Co., Ltd.
No.3857 Sixian Road, Songjiang District, Shanghai,
P.R.China

Note: When more than one factory, please report on page 2
Note: Lorsque plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

See the Appendix

Trademark (if any)
Marque de fabrique (si elle existe)

CHINT

Model / Type Ref.
Ref. De type

NA8-2500H

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

PUBLICATION
IEC 60947-2:2016(5th Edition)

EDITION

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

00901-CB2017CQC-078449

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



CHINA QUALITY CERTIFICATION CENTRE

Date: Oct.31,2018

Signature:

Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86-10-83886666
Fax: +86-10-83886282

website
www.cqc.com.cn

CB 0045854

NA8-2500H
Ui: 1000V
Uimp: 12kV;
Ue: AC380/400/415V, AC690V
In: 630A, 800A, 1000A, 1250A, 1600A, 2000A, 2500A
Over-current release: Electronic
Ics: AC380V/400/415V: Ics=85kA; AC690V: Ics=65kA
Icu: AC380V/400/415V: Icu=85kA; AC690V: Icu=65kA
Icw: AC380V/400/415V: Icw=85kA/1s, Icw=50kA/3s;
AC690V: Icw=65kA/1s, Icw=50kA/3s;
Selectivity category: B;
3P, 4P
IP20(only front)
Auxiliary contact (Body)
4NO4NC, 6NO6NC:
Ith: 6A
AC-15: Ue/Ie: AC230V/1.3A, AC415V/0.75A
DC-13: Ue/Ie: DC110V/0.55A, DC220V/0.27A
Accessories with electronic circuits:
Undervoltage release:
Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;
Shunt release:
Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;
Closing electromagnet:
Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;

Page 1 of 1

Additional information (if necessary)
Information complémentaire (si nécessaire)

Date: Oct.31,2018

Signature:



Wang Kejiao