

IEC**IECEE**
CB
SCHEME

Ref. Certif. No.

CN45654

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Air Circuit Breaker

Name and address of the applicant

Zhejiang CHINT Electric Co., Ltd.
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electric Co., Ltd.
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

NOARK Electrics (Shanghai) Co., Ltd.
No.3857 Sixian Road, Songjiang District, Shanghai,
P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NA8-1600H

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016(5th Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2017CQC-078446

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Jan.04,2019

Signature:

Lu Mei

CB 0049401

NA8-1600H

Uimp:12kV;

Ui:1000V;

Ue: AC380V/400V/415V, AC690V;

In: 400A,6300A,800A, 1000A, 1250A,

1600A;

Over-current release: Electronic;

Ics=55kA(AC380V/400V/415V), 36kA(AC690V);

Icu=65kA(AC380V/400V/415V), 36kA(AC690V);

Icw=42kA/1s(AC380V/400V/415V), 30kA/3s (AC380V/400V/415V),

36kA/1s(AC690V), 30kA/3s(AC690V);

Selectivity category:B;

3P, 4P;

IP20;

Suitability for insulation: 50/60Hz;

Accessories with electronic circuits:

Undervoltage release:

Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;

Shunt release:

Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;

Closing electromagnet:

Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;

Auxiliary contact (Body):

4NO4NC,6NO6NC;

Ui: 500V;

Ith: 6A;


Ue/Ie: AC-15: AC240V/415V/2A;

DC-13: DC110V/220V/0.25A

Page 1 of 1

Additional information (if necessary)

Date: Jan.04,2019

Signature: 

Lu Mei