



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE190303006339

Product Air Circuit Breaker

Applicant Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province

Type/Model NA8-7500, NA8-7500H

Technical data See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
00901-CE2017CQC0303-010393, the submitted sample(s) of the above item complies
with:

EN60947-2:2017

and fulfills testing requirements of the European Directive:
2014/35/EU

Valid from: Jul.12,2019

Valid until: Jul.12,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0009163



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE190303006339

NA8-7500, NA8-7500H

Ui: 1000V;

Uimp: 12kV;

Ue: AC220/380/400/415/440V, AC525/660/690V;

In: 4000A, 5000A, 6300A, 7500A;

Ue	In	type	Ics (kA)	Icu (kA)	Icw (kA) /1s	Icw (kA) /3s
AC220/380/400V/415V/440V	4000A, 5000A, 6300A, 7500A	NA8-7500	135	135	135	100
AC525/660/690V	4000A, 5000A, 6300A, 7500A	NA8-7500	100	100	100	100
AC220/380/400V/415V/440V	4000A, 5000A, 6300A	NA8-7500H	135	150	135	100
AC220/380/400V/415V/440V	7500A	NA8-7500H	150	150	135	100
AC525/660/690V	4000A, 5000A, 6300A, 7500A	NA8-7500H	100	100	100	100

Over current release type: Electronic;

Selectivity category: B

3P, 4P;

Auxiliary contact: 4NO4NC, 6NO6NC

Ith: 6A

AC-15: Ue/Ie: AC230V/1.3A, AC415V/0.75A;

DC-13: Ue/Ie: DC110V/0.55A, DC220V/0.27A;

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.: CE190303006339

Accessories with electronic circuits:

Closing coil: Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V;

Undervoltage release: Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V;

Shunt release: Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V;

Over-current release: Us: AC220-230V, AC380~415V, DC110V, DC220V

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>