CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
CERTIFICATE OF CONFORMITY

Certificate No.: CE250306009570

Product	Automatic Transfer Switching Equipment
Applicant	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Type/Model	NXZHMN-63,NXZHMNP-63,NXZHMNF-63, NXZHM-63,NXZHMP-63,NXZHMF-63; NXZHMN-100,NXZHMNP-100, NXZHMNF-100,NXZHM-100,NXZHMP-100, NXZHMF-100;NXZHMN-125,NXZHMNP-125, NXZHMNF-125,NXZHM-125,NXZHMP-125, NXZHMF-125;
Technical data	Ui:800V; Ue:AC230V/AC240V/AC400V/AC415V; Uimp:8kV(Main circuit),2.5kV(Control Circuit); Ie:10A,16A,25A,32A,40A,50A,63A(NXZHM□□-63); Ie:10A,16A,25A,32A,40A,50A,63A,80A, 100A(NXZHM□□-100); Ie:10A,16A,25A,32A,40A,50A,63A,80A, 100A,125A(NXZHM□□-125); Icw:5000A/30ms, Icm:7650A(NXZHM□□-63); Icw:5000A/30ms, Icm:7650A(NXZHM□□-100); Icw:10000A/30ms, Icm:17000A(NXZHM□□-125); Iq:100kA;50Hz/60Hz; Utilization category:AC-33B;3P,4P; IP30(Except for the wiring terminals); Class PC; ATSE

This is to certify that, on the basis of the tests undertaken as per Report No. (2025)FQIIDQCE-0465, the submitted sample(s) of the above item complies with:

EN IEC 60947-6-1:2023

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Apr.27,2025

Valid until: Apr.26,2028

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn

SIGNATURE: 谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司 1101061026946