



Ref. Certif. No.

CN53801

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded Case Circuit-breakers

Name and address of the applicant

Zhejiang CHINT Electric Co., Ltd.
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electric Co., Ltd.
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Wenzhou CHINT Electrics Technology Co., Ltd.
No.1318, Binhai No.2 Avenue, Economic and Technical Development Zone, Wenzhou City, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NM1-250S

Additional information (if necessary may also be reported on page 2)

IEC 60947-2:2016(5th Edition); IEC 60947-2:2016/AMD1:2019

A sample of the product was tested and found to be in conformity with

00901-CB2021CQC-095777

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE


Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: http://www.cqc.com.cn



Date: Jun.21,2021

Signature: 
Lu Mei

NM1-250S

Uimp:8kV;

Ui:800V;

Ue: AC220V/AC230V/AC240V,AC380V/AC400V/AC415V,AC690V;

In: 100A,125A, 140A, 150A, 160A, 175A, 180A, 200A, 225A, 250A

Over-current release: electro-magnetic, thermo-magnetic;

Ics: 30kA(AC220V/AC230V/AC240V),18kA(AC380V/AC400V/AC415V),4kA(AC690V);

Icu: 50kA(AC220V/AC230V/AC240V),35kA(AC380V/AC400V/AC415V),8kA(AC690V);
50/60Hz

Selectivity category: A;

3P,3P+N(3 protected poles with an uninterrupted neutral pole),

4P(3 protected poles with an interrupted neutral pole),4P;

Applicable for isolation(except for 3P+N);

IP30 (except for the terminals) ;

Auxiliary contact and alarm contact: AX-M, AL-M;

2NO2NC ;

Ith: 3A;

Ue/Ie:

AC-15: AC380V/AC400V/AC415V/0.26A;

DC-13: DC110V/0.14A,DC220V/DC250V/0.14A;

Accessories complied with Annex N:

Undervoltage release: UVT-M3:

Us: AC220V/AC230V/AC240V,AC380V/AC400V/AC415V;

Electric operator: MD-M3:

Us: AC220V/AC230V/AC240V,AC380V/AC400V/AC415V,DC110V,DC220V/DC250V

Page 1 of 1

Additional information (if necessary)

Date: Jun.21,2021

Signature: 

Lu Mei