Ref. Certif. No.

CN55015-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Moulded Case Circuit Breaker
Name and address of the applicant	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the manufacturer	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the factory Note: *When more than one factory, please report on page 2*	NOARK Electrics (Shanghai) Co., Ltd. No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China
Ratings and principal characteristics	See the Appendix
Trademark / Brand (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	NM8N-400HV, NM8N-630HV;
Additional information (if necessary may also be reported on page 2)	Original CB certificate No. is CN55015, dated 2021-10-18. The first modification is to change parameters.
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th Edition)
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2021CQC-099302-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn

Date: May.05,2022

Signature: 谢肇煦
Xie ZhaoXu

CB 0068549

NM8N-400HV, NM8N-630HV
Uimp: 12kV;
Ui: 1250V;
Ue: AC690V, AC800V, AC1000V, AC1150V;
In: 250A, 315A, 350A, 400A, 500A, 630A;
Over-current release type: Thermal-magnetic, Electromagnetic;
Ics: See table below;
Icu: See table below;
Selectivity category: A;
Rated frequency: 50/60Hz;
Suitable for isolation;
3P;
Auxiliary contact: AX21-M8, AL21-M8;
1NO1NC;
Ith: 5A;
AC-15: Ue/Ie: AC110V/5A, AC240V/4A, AC415V/2A;
DC-13: Ue/Ie: DC110V/0.25A, DC220V/0.25A;
Electronic accessories complied with Annex N:
Undervoltage release(Model type: UVT22-M8): AC48V, AC110V, AC220~240V, AC380~415V, DC24V,DC48V, DC110~120V, DC220V

In	Ue	Icu(kA)		Ics(kA)	
		C	S	C	S
250A, 315A, 350A, 400A, 500A, 630A	AC690V	50	80	50	80
	AC800V	36	50	36	50
	AC1000V	25	35	15	20
	AC1150V	10	10	10	10

Additional information (if necessary)

Date: May.05,2022

Signature: 谢肇煦
Xie ZhaoXu

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666
Fax: +86-10-83886282
website
http://www.cqc.com.cn